

Important Announcement

Hot Tub & Spa Circuits

Circuit and Ground Fault Interrupter Requirements for Final Inspection

In the interest of safety, it is the Idaho Division of Building Safety, Electrical Bureau's position that all circuits installed for hot tubs and spas are in accordance with 1999 NEC Article 680-42. Before a final inspection will be made or the installation and permit signed off, G.F.C.I.s are required to be installed with the circuit, even if the hot tub or spa is to be added at a future date.